

January 23, 2009

VAN GOETHEM SEPTIC SYSTEMS, INC.
CONCRETE DEPT.
LONNY VAN GOETHEM
EAST 3055 COUNTY HWY J
KEWAUNEE WI 54216

Re: Description: SEWAGE TANKS, CONCRETE
Manufacturer: VAN GOETHEM SEPTIC SYSTEMS, INC.
Product Name: SEPTIC/SEPTIC, SEPTIC/PUMP, HOLDING OR PUMP TANK
Model Number(s): 995/285 SEPTIC/SEPTIC, 995/285 SEPTIC/PUMP, 1280 HOLDING OR 1325 PUMP TANK
2-COMPARTMENT TREATMENT TANK
(45" L.L., 22.2/6.4 GAL/IN., 48" MAX. DEPTH OF BURY, 617 G.P.D. WHEN USED AS A
SEPTIC/SEPTIC TANK OR 479 G.P.D. WHEN USED AS A SEPTIC TANK BASED ON A 3
YR. SERVICE INTERVAL FOR RESIDENTIAL WASTEWATER)
Product File No: 20090022

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of MAY 2014.**

This approval is contingent upon compliance with the following stipulation(s):

- This product is approved to use the following:
 - Opening cast in riser for electrical wiring.
 - Department approved effluent filter installed in accordance with the product approval for the filter including a properly sized and located access opening for service and maintenance.
 - Pipe materials constructed in conformance with Table 84.30-2 or 84.30-11, Wis. Admin. Code poured into tank wall.
 - "Cast-A-Seal" by Press Seal Gasket Corp.
 - Polypropylene riser and access cover by EZ Set Tank Company
- This tank must be designed to withstand the pressures to which it will be subjected.
- The manufacturer must keep at the manufacturing plant a set of plans and specifications bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.
- When this product has an effluent filter installed in an interior wall, the space between the top of the interior wall and bottom of the tank cover must be sealed with a material that will withstand the environment in the tank and in a manor that will prevent waste from passing over the interior wall.
- When this product receives wastewater from dwellings and is used as a septic tank, it will produce an effluent quality with a maximum monthly average value for BOD5 of greater than 30 mg/L and less than or equal to 220 mg/L TSS, or greater than 30 mg/L or less than or equal to 150 mg/L TSS, and F.O.G. of less than 30 mg/L.

This approval supersedes the approval issued on 5/10/2004 under product file number 20070179.

VAN GOETHEM SEPTIC SYSTEMS, INC.

Page 2

January 23, 2009

PRODUCT FILE NO. 20090022

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20040179.

As of May 15, 2008, a copy of a successful water tightness test report for this product must be AVAILABLE FOR INSPECTION AT THE MANUFACTURER'S PLANT prior to this product being used as a POWTS holding or treatment tank in Wisconsin.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST
Engineering Consultant--Plumbing Product Reviewer
Commerce; Safety & Buildings Div.
PO Box 2658
201 W Washington Ave.
Madison WI 53703-2658
Phone: 608-266-0955; Fax: 608-283-7456
E-mail: Jean.MacCubbin@wisconsin.gov